

**Report no. K 2019 2018 Z1 rev.01**

Supplement to type testing

Heating boilers for solid fuels  
in accordance with  
DIN EN 303-5

Type:  
**SUNPELLET ...**

Trademark:  
**FERROLI**

Company:  
**Ferrol S.p.A.**



**This accreditation is valid only for the listed standards as stated in the accreditation annex of D-PL-11120-04-00.**

**This report may only be published and forwarded to third parties in its complete, unabridged form. The publication or dissemination of extracts, summaries, appraisals or any other adaptation and alterations, in particular for advertising purposes, is only permissible with the prior written permission of TÜV Rheinland.**

**Publication of page 2 is permitted.**

**The test results presented in this report refer solely to the test object stated as described on page 2. The report does not represent a general statement about the serial production of the test object and gives not an authorization for use of a TÜV Rheinland test- / certification mark.**

**Supplement to type testing**  
**Heating boilers for solid fuels acc. DIN EN 303-5: October 2012**  
**Test of the heating requirements**  
**-Test report C-**

Manufacturer: Ferroli S.p.A.  
Via Ritonda 78/A  
I-37047 San Bonifacio (VR)

Trademark: FERROLI

Type designation: SUNPELLET ...

Type of construction: Heating boiler in accordance with DIN EN 303, part 5

Type of fuel: Wood pellets, 6 mm

Type of loading: Automatically

Max. water temperature: 80 °C

Max. water pressure: 3,0 bar

Date of test: 26.02. - 01.03.2018

Type designation:	Heat input [kW]	Heat output [kW]
SUNPELLET 3	6,7 – 24,9	6,4 – 22,0
SUNPELLET 4	9,0 – 33,9	8,6 – 30,0
SUNPELLET 5	11,3 – 40,6	10,7 – 36,0
SUNPELLET 6	13,0 – 47,2	12,4 – 42,0
SUNPELLET 7	14,7 – 54,7	14,0 – 48,0

**Remarks:**

For the constructional requirements of the boiler see the test report K 390 2013 T32 and the burner S 386 2017 E10.

**Test result:**

According DIN EN 303-5:2012, 4.4 Heating requirements. This examination has been carried out by the impartial test centre of TÜV Rheinland in a test laboratory equipped in accordance with DIN EN 304, version 01/04.


Cologne, 30.04.2019  
432/mh

Assessor:

  
M. Sc. M. Höfinghoff

Test Centre for Energy Appliances  
DIN- und DVGW-Laboratory

Report released after review:

  
Dipl.-Ing. R. Verbert